

*This information is not the official version of the Official Compilation of the Rules and Regulations of the State of New York (NYCRR). No representation is made as to its accuracy, nor may it be used as an official business record of the New York State Department of Public Service. To ensure accuracy and for evidentiary purposes, reference should be made to the official NYCRR. The Official NYCRR is available from West Publishing: 1-800-344-5009.*

§ 502.1 Standards

Every water-works corporation shall on or before November 15, 1935, submit for the approval of this commission proposed amendments to its tariff schedules setting forth rules and regulations covering the construction and maintenance of service pipes, such rules and regulations, among other things, to provide:

- (a) The minimum depth at which all service pipes shall be laid. The depth so fixed to be sufficient to prevent freezing.
- (b) The size and kind of pipe and apparatus to be installed, service pipes to be at least three-quarters inch in diameter except under unusual circumstances which shall be clearly defined.
- (c) All connections of service pipes with the transmission mains where the covering over the main is less than five foot shall be made on the side of the main and the service pipe shall in no case have less covering than the main.

§ 502.2 Maintenance of utility-owned service pipe

Such rules and regulations shall in no event require the consumer to maintain any service pipe owned by the water-works corporation.

§ 502.3 Rules to be printed on application form

Such rules and regulations shall either be printed on the service application form or shall be printed on a folder which shall be delivered to every applicant for service.

§ 502.4 Exceptions

Water-works corporations having now on file with this commission rules and regulations in connection with the construction and maintenance of service pipe need not submit such rules except when amendments are necessary to comply with the requirements of this Part.