

BEFORE THE  
STATE OF NEW YORK  
PUBLIC SERVICE COMMISSION

---

In the Matter of

Case 07-M-0906

Joint Petition of Iberdrola, S.A., Energy East Corporation, RGS Energy Group, Inc., Green Acquisition Capital, Inc., New York State Electric & Gas Corporation and Rochester Gas and Electric Corporation for Approval of the Acquisition of Energy East Corporation by Iberdrola, S.A.

---

January 31, 2008

Exhibit \_\_\_\_ (ERP – 1)

Case No. 07-M-0906

Iberdrola, S.A. and Energy East Corp.

Staff Response to Request For Information

STAFF RESPONSE TO: IBER/EE IR No. 142  
PREPARED BY: Electric Reliability and Safety Panel  
DATE: January 28, 2008

Question:

Pages 3-4 of the Electric Reliability and Safety Panel's testimony describes New York State Electric & Gas Corporation's and Rochester Gas and Electric Corporation's SAIFI and CAIDI. Please provide the current electric reliability performance mechanism targets (CAIDI and SAIFI) for National Grid.

1. How many times did National Grid fail to meet one or both reliability targets in the five years preceding the doubling of National Grid's revenue requirement?

Response:

1. The SAIFI and CAIDI targets for National Grid are 0.93 and 2.07, respectively.
2. National Grid failed to meet its established SAIFI and CAIDI targets a total of four times prior to the doubling of the performance mechanism.