



**Public Service
Commission**

2014 ELECTRIC RELIABILITY

Presented By: Tammy Mitchell

Electric Distribution Systems

June 2015

Means to Monitor Service Reliability


- Monthly Interruption Data
- Reliability Performance Mechanism (RPM)

Components to Measure Reliability

- Frequency (SAIFI)
- Duration (CAIDI)
- Major Storms
- Cause Code
 - tree contact, equipment failures, accidents, equipment, lightning, etc.


Statewide Frequency

Statewide Frequency (Excluding Major Storms)



Statewide Duration

Statewide Duration
(Excluding Major Storms)



Con Edison's RPM Targets

- Met its Radial Targets and its Network Frequency Target
- Network Outage Duration Performance above RPM Target
- \$5 million revenue adjustment
- Corrective Actions

RPM Targets

- All Other Utilities met Frequency and Duration RPM Targets