

**New York Standard Approach for Estimating Energy Savings
from Energy Efficiency Programs
(Technical Resource Manual – TRM)**

RECORD OF REVISION					
Revision Number	Issue Date	Effective Date/Range	Measure	Heading/Sub Section of Tech Manual Change or Addition and Brief Description of Change/Addition	Location/Page in Tech Manual (October 15, 2010)
6-13-1	6/30/13	7/1/13 – 9/30/13	Water Heater (Residential)	<i>Method for Calculating Energy Savings</i> Revises the inlet water temperature ('T' mains column) in the accompanying tables for New York City from 62.5 ⁰ to 55 ⁰ (F) AND Inserts row for inlet water temperature ('T' mains column) in accompanying tables for Long Island, to acknowledge difference of water source from NYC. Inlet water temperature for Long Island established at 62.5 ⁰ (F)	Pg. 80
6-13-2	6/30/13	7/1/13 – 9/30/13	Indirect Water Heater (Residential)	Same as above.	Pg. 85
6-13-3	6/30/13	7/1/13 – 9/30/13	Heat Pump Water Heater (Residential)	Same as above.	Pg. 90
6-13-4	6/30/13	7/1/13 – 9/30/13	Low Flow Showerheads (Residential)	Same as above.	Pg. 93
6-13-5	6/30/13	7/1/13 – 9/30/13	Faucet Aerators (Residential)	Same as above.	Pg. 95
6-13-6	6/30/13	7/1/13 – 9/30/13	Water Heaters (Commercial)	Same as above.	Pg. 161
6-13-7	6/30/13	7/1/13 – 9/30/13	Indirect Water Heater (Commercial)	Same as above.	Pg. 166
6-13-8	6/30/13	7/1/13 – 9/30/13	Low Flow Showerheads (Commercial)	Same as above.	Pg. 171
6-13-9	6/30/13	7/1/13-9/30/13	Faucet Aerators (Commercial)	Same as above.	Pg. 173
3-13-1	3/14/13	3/14/13	Appendix O	C&I Lighting Policy	

July 1, 2013

**New York Standard Approach for Estimating Energy Savings
from Energy Efficiency Programs
(Technical Resource Manual – TRM)**

RECORD OF REVISION					
Revision Number	Issue Date	Effective Date/Range	Measure	Heading/Sub Section of Tech Manual Change or Addition and Brief Description of Change/Addition	Location/Page in Tech Manual (October 15, 2010)
5-11-1	5/6/11	5/6/11	Appendix M	Guidelines for Early Replacement Conditions	
Original Issue	10/15/10	1/1/11	Original Issue	Original Issue	Original Issue

**New York Standard Approach for Estimating Energy Savings
from Energy Efficiency Programs
(Technical Resource Manual – TRM)**

Replacement Text Associated with Record of Revision Numbers

Record of Revision Numbers: 6-13-1 through 6-13-9

City	Annual Average outdoor temperature (°F)	T mains (°F)
Albany	48.2	54.2
Binghamton	46.9	52.9
Buffalo	48.3	54.3
Massena	44.7	50.7
Syracuse	48.6	54.6
Upstate Average	47.3	53.3
Long Island	56.5	62.5
NYC	56.5	55