

Company Name: Con Edison
Case Description:
Case: 08-E-0539

Response to NYECC Interrogatories – Set NYECC4
Date of Response: 08/21/2008
Responding Witness: Customer Operations

Question No. :57

For customers with existing interval meters which record hourly consumption are there circumstance(s) in which the Company will not use the actual hourly consumption recorded by the meter? If so, what are these circumstances and for each circumstance provide the rationale for doing so.

Response:

The Company will not use the hourly consumption recorded by existing interval meters when the interval data is invalid or cannot be validated (for example, based on an aggregated consumption check at the end of the billing period).